

FINAL
DRAFT

INTERNATIONAL
STANDARD

ISO/FDIS
23840

ISO/TC 131/SC 8

Secretariat: BSI

Voting begins on:
2021-08-20

Voting terminates on:
2021-10-15

Water hydraulics — Water-hydraulic pumps — Methods of testing and representing basic steady-state performance

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.



Reference number
ISO/FDIS 23840:2021(E)

© ISO 2021



COPYRIGHT PROTECTED DOCUMENT

© ISO 2021

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Symbols and units	2
5 Water	2
6 Tests	2
6.1 Requirements	2
6.1.1 General	2
6.1.2 Installation of the unit under test	3
6.1.3 Test fluid	3
6.1.4 Temperature	3
6.2 Test circuit	3
6.3 Test measurement	4
6.4 Preparation of test	5
6.5 Measurement procedure	5
7 Expression of results	6
Annex A (informative) Errors and classes of measurement accuracy	7
Annex B (normative) Permissible variation of mean indicated values of controlled parameters	9
Annex C (informative) Example of graphs presenting test results	10
Bibliography	14

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 131, *Fluid power systems*, Subcommittee SC 8, *Product testing*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

Water hydraulics or water-hydraulic systems (hydraulic systems in which water is used as the power-transmitting medium in a fluid power system) have potential market demand as they facilitate maintaining cleanness and permit a reduction in fluid cost, machine size and fire risk. Applications of water hydraulics have been expanding into new fields which require cleanness, most notably the cleaning sector, animals and plants, food, packaging, cosmetics and semiconductors, amongst others. This is due to the environmental cleanliness of water compared with alternative hydraulic fluids, such as oil.

Although water hydraulics is a generally well-known concept, there are currently no international standards specialized in water hydraulics. As the technology of water hydraulics is an emerging technology, it is considered a relevant topic for international standardization by related countries, including both developing countries as well as developed ones, and in particular by ISO/TC 131 (Fluid power systems), in order to accelerate the development of this technology.

The water-hydraulic pump is one of the key components of water hydraulics. The development of an appropriate standard for water-hydraulic pumps, which focuses on methods of testing and representing basic steady state performance, is therefore critical to business trade and/or product acceptance by consumers.

Water hydraulics — Water-hydraulic pumps — Methods of testing and representing basic steady-state performance

1 Scope

This document specifies methods for determining the performance and the efficiency of water-hydraulic positive displacement pumps having continuously rotating shafts. This document provides test equipment, a test procedure under steady-state conditions and the presentation of test results.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 4391, *Hydraulic fluid power — Pumps, motors and integral transmissions — Parameter definitions and letter symbols*

ISO 5598, *Fluid power systems and components — Vocabulary*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 4391 and ISO 5598 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1

water-hydraulic pump

positive displacement pump that transforms mechanical energy into water-hydraulic energy with water as the system fluid

3.2

flow rate of the pump under test

flow rate measured at the outlet port of the pump under test

3.3

pump volumetric efficiency

ratio of the effective output flow rate to the derived output flow rate

3.4

hydromechanical pump efficiency

ratio of the derived torque to the effective torque

3.5

inlet gauge pressure of the pump under test

measured gauge pressure at or near the suction port of the pump under test

Note 1 to entry: The value of “inlet gauge pressure of the pump under test” shows either positive or negative.

3.6

outlet gauge pressure of the pump under test

measured gauge pressure at or near the delivery port of the pump under test

3.7

tap water

water supplied through pipes or tubes to taps/faucets

3.8

total dissolved solids

TDS

weight of inorganic and organic matter in true solution per unit volume of water

4 Symbols and units

For the purposes of this document, the symbols and units listed in [Table 1](#) apply. In [Table 1](#), as the unit of derived capacity and shaft speed, m^3 and s^{-1} , as well as m^3/rev and rev/s , may be used.

Table 1 — Symbols and units

Description	Symbols	Unit
Pump overall efficiency	η_t	-
Hydromechanical pump efficiency	η_m	-
Pump volumetric efficiency	η_v	-
Rotational frequency	n	rev/s
Inlet gauge pressure of the pump under test	$p_{e,i}$	Pa
Outlet gauge pressure of the pump under test	$p_{e,o}$	Pa
Flow rate of the pump under test	q_p	m^3/s
Effective torque	t_e	N·m
Water temperature	T_w	K
Derived capacity	V_i	m^3/rev

5 Water

Tap water can be used for the working fluid of water-hydraulic systems including a water-hydraulic pump.

6 Tests

6.1 Requirements

6.1.1 General

Installations shall be designed to prevent air entrainment during operation and measures shall be taken to remove free air from the system before testing.

The tank height level should be designed to be higher than the pump suction port, in order to prevent the reduction of the suction pressure.

Tap water shall be supplied through a filter with the specified filtration performance (10 microns) whilst tap water is supplied to a hydraulic tank.

[Figure 1](#) illustrates the basic circuit for the test of a water-hydraulic pump. This figure does not incorporate all the safety devices necessary to protect against damage in the event of any component fracture or fragmentation. Those who are responsible for carrying out the test shall give due consideration to safeguarding both personnel and equipment.

6.1.2 Installation of the unit under test

The test circuit shall be constructed in accordance with [Figure 1](#).

6.1.3 Test fluid

Working fluid of water hydraulics shall be tap water. Additional additives shall not be added.

6.1.4 Temperature

Tests shall be carried out at a stated test fluid temperature. The test fluid temperature shall be measured in a tank or at the pump inlet. The position of the temperature measurement shall be determined by the manufacturer and user of the pump under test. Water temperature shall be controlled by heat exchanger within the range recommended by the manufacturer. Measurements shall be made at temperature levels 20 °C to 40 °C.

The test fluid temperature shall be maintained within the limits stated in [Table 2](#). The temperature tolerance (either A, B, or C) shall be recorded.

Table 2 — Indicated test fluid temperature tolerance


Temperature accuracy class (see Annex A)	A	B	C
Temperature tolerance (°C)	±1,0	±2,0	±4,0

6.2 Test circuit

The test circuit shown in [Figure 1](#) shall be used.

The first shut-off valve (Key 14 of [Figure 1](#)) is closed and the second shut-off valve (Key 13) is opened when the inlet port of the pump under test is pressurized by a boost pump (Key 7). The inlet pressure of the pump under test is adjusted by a pressure relief valve (Key 8).

The water level in a tank from the pump inlet port shall be kept up within a given range (e.g. 0,8 m to 1,0 m). A boost pump (Key 7) may be provided to keep the inlet pressure within an acceptable range, which shall be determined by the manufacturer and user of the pump under test, in case there is a demand for pressurized inlet port as a measure to prevent the occurrence of cavitation.



Key

- | | | | |
|---|-----------------------|----|---|
| 1 | pump under test | 8 | pressure relief valve (boost pump) |
| 2 | torque meter | 9 | pressure relief valve (pump under test) |
| 3 | tachometer | 10 | flowmeter |
| 4 | AC servo motor | 11 | heat exchanger |
| 5 | outlet pressure gauge | 12 | temperature transducer |
| 6 | inlet pressure gauge | 13 | shut-off valve (boost pump) |
| 7 | boost pump | 14 | shut-off valve (pump under test) |

Figure 1 — Test circuit for pump

6.3 Test measurement

A test report shall contain at least the following six measured results:

- a) effective torque
- b) rotational frequency
- c) flow rate of the pump under test
- d) outlet gauge pressure of the pump under test
- e) inlet gauge pressure of the pump under test
- f) water temperature

6.4 Preparation of test

The preparation shall be completed in advance, before beginning a test, according to the following procedure using the test circuit shown in [Figure 1](#):

- 1) Power the test setup.
- 2) Start the cooling system and set the temperature to a specified value in the range of 20 °C to 40 °C.
- 3) Set the rotational frequency to the minimum working rotational frequency (e.g. 500 min⁻¹) and verify no-leak of water under the condition that the main relief valve (pressure relief valve, Key 9 of [Figure 1](#)) is fully released. Increase the rotational frequency gradually (e.g. 900, 1 300, 1 700 min⁻¹, etc.) to the maximum working rotational frequency (e.g. 1 800 min⁻¹) after a few minutes of operation (e.g. three minutes) at the minimum working pressure. Verify no-leak of water. Verify that no abnormal noise and no abnormal vibration of the pump and other components are observed.
- 4) Increase the pump outlet pressure to the maximum working pressure (e.g. 16 MPa) with the rotational frequency kept at the maximum working rotational frequency (e.g. 1 800 min⁻¹), by adjusting the main relief valve (pressure relief valve, Key 9),
- 5) Maintain the condition of 4) for a few minutes (e.g. three minutes).
- 6) Stop the preparation operation by using the following procedures a) and b) when water temperature and effective torque show steady-state values.
 - a) Decrease the outlet gauge pressure of the pump under test by fully releasing the main relief valve (pressure relief valve, Key 9).
 - b) Decrease the rotational frequency until the pump is stopped.

6.5 Measurement procedure

Pump basic steady-state performance shall be measured in the rotational frequency range of the minimum to maximum working rotational frequencies (e.g. 500 min⁻¹ to 1 800 min⁻¹) and in the outlet gauge pressure range of the minimum to maximum working pressures (e.g. the pressure obtained by fully releasing the main relief valve (Key 9 of [Figure 1](#)) to 16 MPa).

Measurement shall be taken according to the following procedure using the test circuit shown in [Figure 1](#).

- 1) Set the rotational frequency of the pump under test to the minimum working rotational frequency (e.g. 500 min⁻¹).
- 2) Set the outlet gauge pressure of the pump under test to the pressure obtained by fully releasing the main relief valve (Key 9).
- 3) Measure the effective torque and rotational frequency by a torque meter (Key 2) and a tachometer (Key 3), respectively, after their values have reached steady-state ones.
- 4) Measure the inlet gauge pressure, outlet gauge pressure and flow rate of the pump under test by an inlet pressure gauge (Key 6), an outlet pressure gauge (Key 5) and by a flowmeter (Key 10), respectively.
- 5) Set the outlet gauge pressure of the pump under test to a specified value (e.g. 1, 2, 3, ... MPa) by adjusting the main pressure relief valve (Key 9).
- 6) Repeat the procedures 3) to 5) up to the maximum working pressure (e.g. 16 MPa) with the rotational frequency kept at a constant.
- 7) Repeat the procedures 2) to 6) at increased rotational frequencies up to the maximum rotational frequency (e.g. 1 800 min⁻¹).

8) Finish the test when measurements at the maximum rotational frequency are taken.

In each case, each set of readings taken for measurement shall be recorded when the indicated value is within the permissible variation of mean indicated values of controlled parameters, in accordance with [Annex B](#)).

7 Expression of results

All test measurements and the results of the calculations derived from measurements shall be tabulated by the testing agency and presented graphically.

For a pump tested, graphs shall contain at least the following three data elements:

a) pump volumetric efficiency, calculated according to [Formula \(1\)](#):

$$\eta_v = \frac{q_p}{V_i n} \quad (1)$$

b) hydromechanical pump efficiency, calculated according to [Formula \(2\)](#):

$$\eta_m = \frac{V_i (p_{e,o} - p_{e,i})}{2\pi t_e} \quad (2)$$

c) pump overall efficiency, calculated according to [Formula \(3\)](#):

$$\eta_t = \eta_v \eta_m \quad (3)$$

The parameters shall be recorded (see [Table C.1](#)).

Annex A (informative)

Errors and classes of measurement accuracy

A.1 Classes of measurement accuracy

Depending on the accuracy required, the test shall be carried out in accordance with one of three classes of measurement accuracy, A, B or C, as agreed between the parties concerned.

NOTE Classes A and B are intended for special cases when it is necessary to have the performance precisely defined.

Attention is drawn to the fact that classes A and B require the use of more accurate apparatus and methods, which increases the test cost.

A.2 Errors

Any device or method used shall, by calibration or comparison with international standards, have been proven to be capable of measuring the given values with systematic errors not exceeding the limits given in [Table A.1](#).

Table A.1 — Measuring instrument permissible systematic calibration errors

Measuring instrument parameter	Permissible systematic error for classes of measurement accuracy		
	A	B	C
Rotational frequency (%)	±0,5	±1,0	±2,0
Torque (%)	±0,5	±1,0	±2,0
Volume flow rate (%)	±0,5	±1,0	±2,0
Pressure MPa (bar) gauge where $p < 0,15$ (1,5)	±0,001 (±0,01)	±0,003 (±0,03)	±0,005 (±0,05)
Pressure MPa (bar) gauge where $p \geq 0,15$ (1,5)	±0,05 (±0,5)	±0,15 (±1,5)	±0,25 (±2,5)
Temperature (K)	±0,5	±1,0	±2,0
Mechanical power (%)	—	—	±4,0
NOTE 1 The percentage limits apply to the value of the measured quantity and not to the maximum test value or the maximum reading of the instrument.			
NOTE 2 The mean indicated value of an instrument reading can differ from the true mean absolute value of the quantity being measured because of inherent and constructional limitations of the instrument and because of the limitations of its calibrations; this source of uncertainty is called "systematic error".			

A.3 Combination of errors

When calculations of power or efficiency are made, the combination of errors involved in the calculation may be determined by the root mean square method including all errors measured and used in calculation parameters. See [Formula \(A.1\)](#):

$$\text{EXAMPLE } \frac{\partial \eta_v}{\eta_v} = \sqrt{\left(\frac{\partial q_p}{q_p}\right)^2 + \left(\frac{\partial V_i}{V_i}\right)^2 + \left(\frac{\partial n}{n}\right)^2} \quad (\text{A.1})$$

The systematic errors used above, ∂q_p , ∂V_i , and ∂n , are the systematic instrument errors and not the maximum values given in [Table A.1](#). For a more precise summation of errors, see ISO 1219-1.

Annex B (normative)

Permissible variation of mean indicated values of controlled parameters

[Table B.1](#) shows permissible variation of mean indicated values of controlled parameters.

Each set of readings taken for a controlled value of a selected parameter shall be recorded only where the indicated value of the controlled parameter is within the limits shown in [Table B.1](#). If multiple readings of a variable are recorded the mean values shall be documented while the controlled parameter is within the operating limits.

Table B.1 — Permissible variation of mean indicated values of controlled parameters

Parameter	Permissible variation for classes of measurement accuracy ^a (see Annex A)		
	A	B	C
Rotational frequency, %	±0,5	±1,0	±2,0
Torque, %	±0,5	±1,0	±2,0
Volume flow rate, %	±0,5	±1,5	±2,5
Pressure, Pa ($p_e < 2 \times 10^5$ Pa) ^b	$\pm 1 \times 10^3$	$\pm 3 \times 10^3$	$\pm 5 \times 10^3$
Pressure, % ($p_e \geq 2 \times 10^5$ Pa)	±0,5	±1,5	±2,5

^a The permissible variations listed in this table concern deviation of the indicated instrument reading and do not refer to limits of error of the instrument reading; see [Annex A](#). These variations are used as an indicator of steady-state and are also used where graphical results are presented for a parameter of fixed value. The actual indicated value should be used in any subsequent calculation of power, efficiency or power losses.

^b 1 Pa = 1 N/m².

Annex C (informative)

Example of graphs presenting test results

C.1 General

This annex shows examples of graphs representing test results of a water-hydraulic pump.


[Figures C.1](#), [C.2](#), and [C.3](#) represent examples of pump volumetric efficiency, hydromechanical pump efficiency, and pump overall efficiency, respectively. In [Figures C.1](#), [C.2](#), and [C.3](#), the open circle (○), open diamond (◇), open square (□), open triangle (△), and cross mark (x) show pump efficiency data in a condition of 500 min⁻¹, 900 min⁻¹, 1 300 min⁻¹, 1 700 min⁻¹, and 1 800 min⁻¹, respectively.

[Table C.1](#) denotes a suggested table for data-recording (example).

[Table C.2](#) shows contents of tap water used in water hydraulics (example).

C.2 Pump volumetric efficiency

[Figure C.1](#) shows an example of a plot representing test results of pump volumetric efficiency of a water-hydraulic pump.




Key

- X pressure difference ($p_{e,o} - p_{e,i}$) (MPa)
- Y pump volumetric efficiency (%)

Figure C.1 — Example of a plot representing test results of pump volumetric efficiency of a water-hydraulic pump

C.3 Hydromechanical pump efficiency

Figure C.2 shows an example of a plot representing test results of hydromechanical pump efficiency of a water-hydraulic pump.




Key

- X pressure difference ($p_{e,o} - p_{e,i}$) (MPa)
- Y hydromechanical pump efficiency (%)

Figure C.2 — Example of a plot representing test results of hydromechanical pump efficiency of a water-hydraulic pump

C.4 Pump overall efficiency

Figure C.3 shows an example of a plot representing test results of pump overall efficiency.



Key

- X pressure difference ($p_{e,o} - p_{e,i}$) (MPa)
- Y pump overall efficiency (%)

Figure C.3 — Example of a plot representing test results of pump overall efficiency of a water-hydraulic pump

C.5 Suggested table for data-recording

Table C.1 shows an example of a suggested table for data-recording.

Table C.1 — Suggested table for data-recording (example)

Rotational frequency n (rev/min)	Derived capacity of the water-hydraulic pump $V_i = X \text{ cm}^3/\text{rev}$																	
	$p_{e,o}$ in MPa	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
500	T_w in °C																	
	$p_{e,i}$ in MPa																	
	q_p in L/min																	
	t_e in N·m																	
	η_v																	
	η_m																	
	η_t																	
900	T_w in °C																	
	$p_{e,i}$ in MPa																	
	q_p in L/min																	
	t_e in N·m																	
	η_v																	
	η_m																	
	η_t																	

Table C.1 (continued)

Rotational frequency n (rev/min)	Derived capacity of the water-hydraulic pump $V_i = X \text{ cm}^3/\text{rev}$																	
	$p_{e,o}$ in MPa	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
1 300	T_w in °C																	
	$p_{e,i}$ in MPa																	
	q_p in L/min																	
	t_e in N·m																	
	η_v																	
	η_m																	
	η_t																	
1 700	T_w in °C																	
	$p_{e,i}$ in MPa																	
	q_p in L/min																	
	t_e in N·m																	
	η_v																	
	η_m																	
	η_t																	
1 800	T_w in °C																	
	$p_{e,i}$ in MPa																	
	q_p in L/min																	
	t_e in N·m																	
	η_v																	
	η_m																	
	η_t																	

C.6 Contents of tap water used in water hydraulics

Table C.2 shows some contents of tap water used in tests of a water-hydraulic pump, exemplified as Figures C.1, C.2, and C.3. Items of Table C.2 are cited from Reference [8].

Table C.2 — Contents of tap water used in water hydraulics

Item	Unit	Criteria
Concentration of hydrogen ion	pH	5,8 ~ 8,6
Hardness (Ca, Mg etc.)	mg/L	300 or less
Chloric ion	mg/L	200 or less
TDS	mg/L	500 or less
General bacteria	count/mL	100 or less

Bibliography

- [1] ISO 1219-1, *Fluid power systems and components — Graphical symbols and circuit diagrams — Part 1: Graphical symbols for conventional use and data-processing applications*
- [2] ISO 4409, *Hydraulic fluid power — Positive-displacement pumps, motors and integral transmissions — Methods of testing and presenting basic steady state performance*
- [3] ISO 8426, *Hydraulic fluid power — Positive displacement pumps and motors — Determination of derived capacity*
- [4] ISO 9110-1, *Hydraulic fluid power — Measurement techniques — Part 1: General measurement principles*
- [5] ISO 9110-2, *Hydraulic fluid power — Measurement techniques — Part 2: Measurement of average steady-state pressure in a closed conduit*
- [6] ISO 11631, *Measurement of fluid flow — Methods of specifying flowmeter performance*
- [7] ISO 16345, *Water-cooling towers — Testing and rating of thermal performance*
- [8] Ministry of Health, Labor and Welfare, Japan, Ministerial Ordinance No. **101**, 30 May 2003, Ministerial Ordinance on Water Quality Standards
- [9] TATSUYA UCHIDA, YUHI YOSHIDA, KAZUSHI SANADA, Yokohama National University. TEST METHODS OF WATER HYDRAULIC PUMPS. Japan: The 10th JFPS International Symposium on Fluid Power, FUKUOKA 2017, 2D55, 24 - 27 October 2017

